



To: Preston Williams, Superintendent

CC: Board of Education,
Carol Baker, Administrative Director
Business

From: Ota Dossett, Administrative Director
Facilities Services

Date: 3/17/2010

Re: Approval of Emergency Life Safety Application Wiley Elementary

The 2.5" domestic water line coming from the 4" water supply main has deteriorated over the last 50 years and has ruptured twice during the week of 2/24/. The condition of this line (which is feed outside the building underground to the north and south end of the building underground) is very unstable. The freeze/ thaw has broken the line and ruptured again after the first break was repaired. During the outage there is no drinking water and no water for the kitchen. Over Spring Break March 22-26 we plan to tie into the 4" line and bring the distribution lines inside the building to eliminate the buried water lines underground that are deteriorated.

Staff recommendation is to authorize life safety application and work to be completed. The overall cost is \$47,000.